CONFIGURATION

MAIN PAGE

On this menu, the user can overview system operations.

×

The menus can be changed on the right side of the window.

Icons color meaning					
×		Gray	This condition	on doesn't have to be met because it's disabled	
×		Grayed out	This condition	on is enabled, but it can't be met right now	
×		Yellow	This condition	on must be met and is waiting for the person to do it	
×		Green	Everything i	is okay, you're clear to enter	
×		Orange	From now o	n you can enter only with L2 allowance	
×		Red	Something i	is wrong, you must not enter	
St	Status overview				
×	Cccupation status and limit		nd limit	It shows occupied status and remaining count to the people	limit of
×	× Disinfector status			It shows if person had applied a disinfector	
×	× Allowance status			It shows if person has a fever and if he wears a facer	nask
×	Card reader			It shows if the use of entry card is needed and the user's level of access	
×	Confirmation status			It shows if the receptionist had left you in and the pe of access	erson's level
×	Enter status			It shows if person should enter or exit	

×

This is the gate status overview.

Gate status overview		
1	Door sensors	It TOF sensor detects person, the entrance sensor (right) turns on for the people coming in, or the exit sensor (left) turns on for the people going out
2	Semaphore status	If both red and green light are turned on, the entrance conditions must be met (card, face sensor, disinfector,), if the green light is turned on you can enter, if the red light is turn on you can't enter. If the semaphore beeper is turned on along with a red light, the person must exit the building immediately. Beeper can be disabled on the System setup menu or it can be set that it resets when the person exits the building
3 Gate status It shows if gates are closed or open		It shows if gates are closed or open
4	Presence status	It shows if the presence sensor has been triggered

5 Thermo and mask camera status	It shows if person has a fever and if he wears a face mask. It can be set, in the System setup menu, on permission mode, which means the doors are closed and they open if you pass the temperature and mask condition (among the others). Or it can be set on prevention mode, which means the doors are open, but they close if you don't pass that condition.
6 Disinfector status	It shows if a person applied disinfector
7 Code reader	It shows the status of access
Configuration	
Set count	Set count for total number of people counted in space
Confirm L1	If the condition for L1 access are met, the button will become enabled
Confirm L2	If the condition for L2 access are met, the button will become enabled
Reset alarm	Resets alarm
Gate auto/gate opened	Switches between gates opening automatically with security measures or opening manually. When they can be opened manually it usually means it's because of emergency and everyone must leave the building immediately

ACCESS SETTINGS

On this menu, the code and access status can be added.

×

Configur	Configuration	
Edit code	Manually input new user's code, alternatively you can scan it with the card scanner	
Туре	Set user level of access, which are L1 for normal users, L2 for VIPs and UL unlimited access (employees)	
Code list	All the users are saved here, choose user to edit it's code and type, holds up to 100 users	
Search Checks the code list for desired code, which the user inputs in the ecsection. The code number and type are then returned.		
Save	Saves the created edit code	
Clear	Clears the edit code and type	
Delete	Deletes the code from the code list	

SYSTEM SETUP

When the system is connected and turned on, the technician sets these settings.

×

Configuration		
Limit 1	This is the limit for normal access, everyone can enter. After this limit is reached, only VIPs and employees can enter (no more L1 access)	
Limit 2	This is the limit for VIP access, L2 and UL can enter. After this limit is reached, only employees can enter (UL access only)	
Counting type	Choose if the counting of people is with digital IO or communication	
Presence time-out	Set how long the presence sensor is active after detecting someone	

http://wiki.hiq-home.com/

Entry gate time-o		et how long the entry doors are open after the TOF sensor has etected someone
Exit gate time-out		et how long the exit doors are open after the TOF sensor has etected someone
Alarm duration S		ets duration time of the alarm
Alarm beeper enabled		nable or disable alarm beeper
Reset alarm on e	xit Er	nable or disable the reset of alarm on exit
allowance cond	lition ı	have to be met if everything is enabled: disinfection and must be met and then just one of other two conditions eans either reader or confirmation condition.
Disinfection		Sets if disinfection is necessary for user's level of access, sets time-out that triggers after check
Allowance		Sets if face mask and temperature check is necessary for user's level of access, sets time-out that triggers after check
Reader		Sets if scanning card on the reader is necessary for user's level of access, sets time-out that triggers after check
Confirmation		Sets if receptionist confirmation is necessary for user's level of access, sets time-out that triggers after check
Allowance type		If set on permission, door opens when user is clear to enter after ok allowance check, if set on prevention, door closes when users fails allowance check
Internet access	5	
Enable push to server		able connection to the cloud server (allow controller to send riodical push message to server) every 30 seconds
Test		nd push message instantly
Reset	Re	eset number of sent messages
Push timer	Sh	ows countdown after which the push message will be sent
Messages		Imber of all sent messages and number of successfully sent essages
Roundtrip		ne it takes the message to get to server and the response to me back
Master code	code i code i scann they a code i be del	
send LAN code sen		nned code is not on the code list for that device, a query will be o other devices in the system. If it gets the response from other e, that the code is on it's list, access is granted
Process LAN		e to process code query and send back answer
LAN query Set q		uery timeout. If the device that sent query doesn't get answer in me, it refuses access
Autodetect It searches for other controllers in the network and opens a menu		rches for other controllers in the network and opens a menu with controllers. If the other controller is chosen, you manage this one
Parameters configuration		
Init parameters	Set pa	arameters to the ones saved in permanent memory
	· · ·	· · ·

Save parameters	Save set configuration to the permanent memory	
Pood parameters	Read parameters from the permanent memory and write them to work parameters	1
	parameters	

DISPLAY SETTINGS

×

Paramet	ers configu	uration for alphanumeric display
Line 1		
Presence		Set text that will be displayed on first line when proximity detector detects someone
Advertising 01-09		Set text that will be displayed when proximity detector isn't detecting anybody
Advertisir	ng text time	Set timer at which the advertising text changes
Line 2		
Counters		Displays number of people with L1 and with L2 access in the building
Line 3		
Enter		Set the text that will be displayed when person is allowed to enter
Disinfect		Set the text that will be displayed when person has to disinfect hands
Camera		Set the text that will be displayed when person has to look at the camera
Confirm		Set the text that will be displayed when waiting for confirmation to enter
Code		Set the text that will be displayed when person has to scan the code
Occupied		Set the text that will be displayed as long as the limit of people inside is reached
Fever		Set the text that will be displayed if fever is detected
Exit		Set the text that will be displayed if the person has to exit the building
Paramet	ers configu	uration for graphic display
Caption		
Full	Set text tha	at will be displayed if the place is full
Level 2		at will be displayed when the limit of people for L1 access is reached eople with L2 access are allowed to enter
Level 1		
		at will be displayed if alarm is triggered
		at will be displayed if warning is triggered
Text		
Enter Set the text		t that will be displayed when person is allowed to enter
Disinfect	fect Set the text that will be displayed when person has to disinfect hands	
Camera	Set the text	t that will be displayed when person has to look at the camera
Confirm	Set the text	t that will be displayed when waiting for confirmation to enter
Code	ode Set the text that will be displayed when person has to scan the code	

Occupied	Set the text that will be displayed as long as the limit of people inside is reached		
Fever	Set the text that will be displayed if fever is detected		
Exit	Set the text that will be displayed if the person has to exit the building		

From: http://wiki.hiq-home.com/ -

Permanent link: http://wiki.hiq-home.com/doku.php?id=en:3s:configuration&rev=1592816583



Last update: 2020/06/22 09:03